

Electrical Requirements

RCD Supply, Connection and Rough-in

RCD Supply

Amuheat floor heating installations must be connected to a supply with an approved Residual Current Device (RCD) mounted on the switchboard. It is recommended you consult with your electrician to ascertain whether or not the circuit and cabling can handle the additional load and if a RCD is protecting the circuit.

Electrical Connection

All electrical connections (including thermostats) must be performed by your electrician, in accordance with current AS/NZ 3000 wiring rules.

Electrical Rough In

